<b>NOTICE OF </b>	PRODUCT CERTIFICA	ΓΙΟΝ
NOS ACCREDITED		
Survey Conception and Conception of the second seco	<b>CERTIFICATION NO:</b>	<u>NI011973.02-R2</u>
	DATE:	03/13/2019
A CALLE	<b>CERTIFICATION PROGRAM:</b>	<u>Structural</u>
ANAGEMENT INSTITUT	<b>COMPANY:</b>	Nan Ya Plastics
CEATING DROPUCT	CODE:	<u>661-1</u>
	<b>REVISION DATE:</b>	01/30/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
Nan Ya Plastics Corporation U.S.A.	Series "SLPS"		
8989 North Loop East	In-Swing 3/4 Lite Glazed Fiberglass		
Houston, TX 77029	Side-Hinged Patio Door (Non-Impact)		
	Configuration: OXX/O Glazing: Insulating Glass (Tempered)		
	Frame: W-3635mm(143.12") H-2096mm(82.5")		
	Panel: W-876mm(34.5") H-2008mm(79.06")		
	DLO: W-641mm(25.25") H-1200mm(47.25")		

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 3635 x 2096 (143 x 82)-SHD Design Pressure: 1915 Pa (40 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf)

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-210-3934-02 March 31, 2036

>

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023