

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011980.03-R3
DATE: 05/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Can-Save
CODE: 1347-1
REVISION DATE: 03/17/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Can-Save Building Materials 411 Bayview Drive Barrie, ON L4M 6P4	<p style="text-align: center;">"Doorsmith Entrance"</p> <p style="text-align: center;">In-Swing Glazed Steel w/Wood Edge</p> <p style="text-align: center;">Side-Hinged Door</p> <p style="text-align: center;">w/Insert Glazing & Articulating Cap</p> <p style="text-align: center;">Configuration: XX Glazing: Insulated Glass (Tempered)</p> <p>Frame: W-1878mm(73.93") H-2481mm(97.67")</p> <p>Panel: W-908mm(35.75") H-2413mm(95.00")</p> <p>DLO: W-584mm(23.00") H-2057mm(81.00")</p>

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG40 1878 x 2481 (74 x 98)-SHD Positive Design Pressure: 2160 Pa (45 psf) Negative Design Pressure: 2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.00 psf) Canadian Air Infiltration/Exfiltration Level: A3 Qualifies Configurations: X/XX

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-110-17014-3/W-1680/W-1681/W-1726
 Expiration Date: **January 31, 2026**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122