
NOTICE OF PRODUCT CERTIFICATION



To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Can-Save Building Materials	"Doorsmith Entrance"
411 Bayview Drive	Out-Swing Glazed Steel w/Wood Edge
Barrie, ON L4M 6P4	Side-Hinged Door
	w/Insert Glazing
	Configuration: XX Glazing: Insulated Glass (Tempered)
	Frame: W-1878mm(73.93") H-2481mm(97.67")
	Panel: W-908mm(35.75") H-2413mm(95.00")
	DLO: W-584mm(23.00") H-2057mm(81.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG45 1878 x 2481 (74 x 98)-SHD Positive Design Pressure: 2160 Pa (45 psf) Negative Design Pressure: 2160 Pa (45 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Canadian Air Infiltration/Exfiltration Level: A3 Qualifies Configurations: X/XX

Product Tested By:National Certified Testing LaboratoriesReport No:NCTL-110-17014-4/W-1680/W-1681/W-1726

Report No: Expiration Date:

January 31, 2026



Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122