

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011980.07-R3  
**DATE:** 05/20/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Can-Save  
**CODE:** 1347-1  
**REVISION DATE:** 03/17/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Can-Save Building Materials</b>  <b>411 Bayview Drive</b>  <b>Barrie, ON L4M 6P4</b>	<p style="text-align: center;"><b>"Doorsmith Entrance"</b></p> <p style="text-align: center;"><b>In-Swing Glazed Steel w/Wood Edge</b></p> <p style="text-align: center;"><b>Side-Hinged Door</b></p> <p style="text-align: center;"><b>w/Insert Glazing &amp; Adjustable Cap</b></p> <p style="text-align: center;">Configuration: OXO Glazing: Insulated Glass (Tempered)</p> <p>Frame: W-2489mm(112.18")    H-2074mm(81.68")</p> <p>Panel: W-908mm(35.75")    H-2006mm(79.00")</p> <p>DLO: W-584mm(23.00")    H-1651mm(65.00")</p>

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class R-PG45 2850 x 2075 (112 x 82)-SHD</b> <b>Positive Design Pressure: 2160 Pa (45 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 330 Pa (6.75 psf) <b>Canadian Air Infiltration/Exfiltration Level: A3</b> Qualifies Configurations: O/X/OX/XO/OXO

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-110-17014-5/W-1680/W-1681/W-1726  
 Expiration Date: **January 31, 2026**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Fax: (804) 684-5122