NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI011980.07-R4
DATE: 05/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Can-Save
CODE: 1347-1
REVISION DATE: 09/11/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Can-Save Building Materials **411 Bayview Drive** **Barrie, ON L4M 6P4**	**"Doorsmith Entrance"** **In-Swing Glazed Steel w/Wood Edge** **Side-Hinged Door** **w/Insert Glazing & Adjustable Cap** Configuration: OXO Glazing: Insulated Glass (Tempered) Frame: W-2489mm(112.18") H-2074mm(81.68") Panel: W-908mm(35.75") H-2006mm(79.00") DLO: W-584mm(23.00") H-1651mm(65.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **CSA A440S1-09**	**Class R-PG45 2850 x 2075 (112 x 82)-SHD** **Positive Design Pressure: 2160 Pa (45 psf)** **Negative Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 330 Pa (6.75 psf)** **Canadian Air Infiltration/Exfiltration Level: A3** Qualifies Configurations: O/X/OX/XO/OXO

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17014-5/W-1680/W-1681/W-1726
Expiration Date: **January 31, 2031**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com