

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011980.10-R5
DATE: 05/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Can-Save
CODE: 1347-1
REVISION DATE: 09/11/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Can-Save Building Materials 411 Bayview Drive Barrie, ON L4M 6P4	“Doorsmith Entrance” In-Swing Glazed Steel w/Wood Edge Side-Hinged Door w/Insert Glazing & Adjustable Cap Configuration: OXO Glazing: Insulated Glass (Tempered) Frame: W-2489mm(112.18") H-2481mm(97.68") Panel: W-908mm(35.75") H-2413mm(95.00") DLO: W-584mm(23.00") H-2057mm(81.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG35 2850 x 2481 (112 x 98)-SHD Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.25 psf) Canadian Air Infiltration/Exfiltration Level: A3 Qualifies Configurations: O/X/OX/XO/OXO

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17014-7/W-1680/W-1681/W-1726
Expiration Date: **January 31, 2031**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023