

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012006-R6
DATE: 07/07/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "M85" Aluminum Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1803mm(71") H-1524mm(60") Panel: W-909mm(35.75") H-1473mm(58") DLO: W-813mm(32") H-1391mm(54.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG30 1803 x 1524 (71 x 60)-HS HS-C30 1803 x 1524 (71 x 60) Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 220 Pa(4.60 psf)

Product Tested By: Architectural Testing, Inc.
Report No: A6308.01-602-44
Expiration Date: **January 31, 2026**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com