NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012007-R8**
DATE:	**06/09/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Wojan**
CODE:	**2087-1**
REVISION DATE:	**03/03/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation **217 Stover Road** **Charlevoix, MI 49720**	**Series "M85"** **Aluminum Fixed Window** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1829mm(72") DLO: W-1410mm(55.5") H-1715mm(67.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class CW-PG65 1524 x 1829 (60 x 72)-FW** **Design Pressure: 3120 Pa (65 psf)** **Negative Design Pressure: 3120 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: C1072.01-602-44-R1
Expiration Date: **July 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com