

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012007.02-R8  
**DATE:** 07/21/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wojan  
**CODE:** 2087-1  
**REVISION DATE:** 03/03/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wojan Window &amp; Door Corporation</b> <b>217 Stover Road</b> <b>Charlevoix, MI 49720</b>	<b>Series "M85 Fixed 2-Wide"</b> <b>Impact Rated Aluminum Fixed Windows</b>  Configuration: OO Glazing: IG-Exterior-1/8" Annealed Glass/0.090 PVB Interlayer by Solutia Saflex/1/8" Annealed Glass/Interior-1/8" Annealed Glass  Frame: W-1524mm(60") H-1981mm(78") DLO: W-673mm(26.5") H-1867mm(73.5")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/E1996-05</b>	<b>Design Pressure: ±2400 Pa (50 psf)</b> <b>Wind Zone 3-Missile Level D</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 93830.01-602-18  
Expiration Date: **June 30, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC 03/30/2023