

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012007.04-R7
DATE: 07/22/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 03/03/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "M85 Fixed 2-Wide" Aluminum Fixed Windows Configuration: OO Glazing: IG-Exterior-Laminate-1/8" Annealed Glass/0.090 PVB Interlayer by Solutia Saflex/1/8" Annealed Glass/Interior-1/8" Annealed Glass Frame: W-1524mm(60") H-1981mm(78") DLO: W-673mm(26.5") H-1867mm(73.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	FW-C50 1524 x 1981 (60 x 78) Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 93830.02-602-18/68135.01-201-44
Expiration Date: **June 30, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023