

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012007.05-R6
DATE: 09/21/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720 | Series "M85" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1829mm(72") DLO: W-1410mm(55.5") H-1715mm(67.5") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 | Class CW-PG30 1524 x 1829 (60 x 72)-FW Design Pressure: ± 3120 Pa (30 psf) Water Penetration Resistance Test Pressure: 220 Pa(4.6 psf) |

Product Tested By: Architectural Testing, Inc.
Report No: C1072.02-602-44-R1
Expiration Date: July 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023 _____