

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012040.01-R3
DATE: 07/01/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1
REVISION DATE: 04/10/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "Kona 3800" Aluminum Casement Window w/5 Hinges Configuration: X Glazing: IG-1/4" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" DuPont SentryGlas Interlayer/1/8" Annealed Glass Frame: W-1067mm(42") H-2135mm(84") Sash: W-952mm(37.5") H-2012mm(79.25") DLO: W-840mm(33.06") H-1908mm(75.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440SI-09 ASTM E1886-05/E1996-06 TAS 201/202/203-94	Class LC-PG65 1067 x 2135 (42 x 84)-C Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 4070 Pa (85 psf) Water Penetration Resistance Test Pressure: 466 Pa(9.75 psf) Canadian Air Infiltration/Exfiltration Level: A3 Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01990817/TEL 01990816/TEL 01990818
Expiration Date: October 31, 2030

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023