

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012040.04-R3
DATE: 07/01/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1
REVISION DATE: 04/10/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Fleetwood Windows and Doors</p> <p>1 Fleetwood Way</p> <p>Corona, CA 92879</p>	<p style="text-align: center;">Series "Kona 3800"</p> <p style="text-align: center;">Aluminum Casement Window</p> <p style="text-align: center;">Configuration: XXX</p> <p style="text-align: center;">Glazing: IG1/4" Tempered Glass/Laminate-1/8" Heat Strengthened Glass/0.090" DuPont Sentryglas Interlayer/1/8" Heat Strengthened Glass or 3/16" Tempered Glass/Laminate-1/8" Heat Strengthened Glass/0.090" DuPont Sentryglas Interlayer/1/8" Heat Strengthened Glass or Monolithic-3/16" Annealed Glass/0.090" DuPont Sentryglas Interlayer/3/16" Annealed Glass</p> <p>Frame: W-3175mm(125") H-2135mm(84")</p> <p>Sash: W-952mm(37.5") H-2012mm(79.25")</p> <p>DLO: W-835mm(32.88") H-1907mm(75.06")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/WDMA/CSA 101/I.S.2/A440-08</p> <p>CSA A440SI-09</p> <p>ASTM E1886-05/E1996-06</p> <p>TAS 201/202/203-94</p>	<p>Class LC-PG65 3175 x 2135 (125 x 84)-C</p> <p>Design Pressure: 3112 Pa (65 psf)</p> <p>Negative Design Pressure: 4070 Pa (85 psf)</p> <p>Water Penetration Resistance Test Pressure: 466 Pa(9.75 psf)</p> <p>Canadian Air Infiltration/Exfiltration Level: A3</p> <p>Wind Zone 4 - Missile Level D</p> <p>Large Missile Impact Rated</p>

Product Tested By: Testing Evaluation Laboratories, Inc.
 Report No: TEL 01990817/TEL 01990816/TEL 01990818
 Expiration Date: October 31, 2030

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/Email: nami@namiinc.com