

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012040.07-R3  
**DATE:** 07/01/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Fleetwood  
**CODE:** 1855-1  
**REVISION DATE:** 04/10/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Fleetwood Windows and Doors</b>  <b>1 Fleetwood Way</b>  <b>Corona, CA 92879</b>	<b>Series "Kona 3800"</b>  <b>Aluminum Casement &amp; Awning Window</b>  Configuration: X/O/X Glazing: Monolithic-1/8" Annealed Glass/0.090" DuPont Sentryglas Interlayer/1/8" Annealed Glass or IG-3/16" Tempered Glass/Laminate-1/8" Heat Strengthened Glass/0.090" DuPont Sentryglas Interlayer/1/8" Heat Strengthened Glass  Frame: W-1067mm(42") H-4572mm(180") Sash: W-1016mm(40") H-1219mm(48") DLO: W-992mm(39.06") H-2073mm(81.62")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440SI-09</b> <b>ASTM E1886-05/E1996-06</b> <b>TAS 201/202/203-94</b>	<b>Class LC-PG65 1067 x 4572 (42 x 180)-AP</b> <b>Design Pressure: 3112 Pa (65 psf)</b> <b>Negative Design Pressure: 3112 Pa (65 psf)</b> <b>Water Penetration Resistance Test Pressure: 466 Pa(9.75 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01990817/TEL 01990816/TEL 01990818  
Expiration Date: October 31, 2030

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023