

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012042.03-R3
DATE: 07/07/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1
REVISION DATE: 04/10/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "Westwood 250" Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Tempered or Heat Strengthened or Annealed) Frame: W-1067mm(42") H-1829mm(72") Sash: W-1016mm(40") H-1790mm(70.5") DLO: W-835mm(32.88") H-1424mm(56.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440SI-09	Class LC-PG65 1067 x 1829 (42 x 72)-C Design Pressure: 3112 Pa (65 psf) Negative Design Pressure: 3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 466 Pa(9.75 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01991056/TEL 01990817/W-1690
Expiration Date: **October 31, 2030**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023