

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012048.01-R3  
DATE: 07/08/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wincore  
CODE: 1640-1  
REVISION DATE: 04/06/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, WV 26104</b>	<b>Series "400/500/5400/5400S" Twin Vinyl</b> <b>Single Hung Windows</b> <b>w/Two-Piece Zero Mullion</b> <b>Replacement Frame</b>  Configuration: O/X/O/X Glazing: Insulating Glass (Annealed)  Frame: W-2032mm(80.00") H-1600mm(63.00") Sash: W-959mm(37.75") H-775mm(30.50") DLO: W-902mm(35.50") H-718mm(28.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG35 2032 x 1600 (80 x 63)-H</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1680 Pa (35 psf)</b> <b>Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: D7348.01-501-47/W-1920  
Expiration Date: April 30, 2031

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124/ Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023