

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012050-R3
DATE: 07/08/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 04/06/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC)

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, WV 26104	Series "7700/9900" Twin Vinyl Double Hung Windows w/Two-Piece Zero Mullion Configuration: X/X/X/X Glazing: Insulating Glass (Annealed) Frame: W-2032mm(80.00") H-1600mm(63.00") Sash: W-933mm(36.75") H-787mm(31.00") DLO: W-838mm(33.00") H-692mm(27.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 2032 x 1600 (80 x 63)-H Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: D7351.01-501-47/W-1920
Expiration Date: April 30, 2031

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Email: nami@namiinc.com

NOPC-03/30/2023