

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012051.06-R5
DATE: 07/14/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1
REVISION DATE: 07/12/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, WV 26104	Series "5400/5400S/7700/9900" Vinyl Sliding Patio Door Configuration: OXO Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.030" PVB Interlayer/1/8" Annealed Glass Frame: W-2700mm(106.29") H-2440mm(96.06") Panel: W-905mm(35.63") H-2332mm(91.81") DLO: W-740mm(29.13") H-2170mm(85.43")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG40 2700 x 2440 (106 x 96)-SD Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 330 Pa(6.75 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Air-Ins, Inc.
Report No: AI-04220-A2/W-1691/W-1920/W-2050
Expiration Date: May 31, 2031

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com