NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION THE CERTIFICATIO	CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE: REVISION DATE:	03/13/2019 Structural Nan Ya Plastics 661-1
TIFIED PRODO	REVISION DATE:	10/25/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
Nan Ya Plastics Corporation U.S.A.	Series "SLPS"		
8989 North Loop East	In-Swing 3/4 Lite Glazed Fiberglass		
Houston, TX 77029	Side-Hinged Patio Door (Non-Impact)		
	Configuration: OXX/O Glazing: Insulating Glass (Tempered)		
	Frame: W-3635mm(143.12") H-2426mm(95.5")		
	Panel: W-876mm(34.5") H-2338mm(92.06")		
	DLO: W-641mm(25.25") H-1607mm(63.25")		

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 3635 x 2426 (143 x 95)-SHD Design Pressure: 1915 Pa (40 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf)

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-210-3973-02 June 30, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122