NOTICE OF PRODU	CT CERTIFICA	ΓION —
1065 ACCREDITED		
Survey and a survey of the sur	CERTIFICATION NO: DATE:	<u>NI012054.02-R2</u> 03/13/2019
CERTI	FICATION PROGRAM:	Structural
TANAGEN USIT	COMPANY:	Nan Ya Plastics
CEATIFIC ROOUCT	CODE:	<u>661-1</u>
THE PRO	REVISION DATE:	04/22/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DES	CRIPTION
Nan Ya Plastics Corporation U.S.A.	Series "SLPS"		
8989 North Loop East	In-Swing 3/4 Lite Glazed Fiberglass		
Houston, TX 77029	Side-Hinged Patio Door (Non-Impact)		
		Configuration: Glazing: Insulating Gla	
	Frame:	W-3635mm(143.12")	H-2426mm(95.5")
	Panel:	W-876mm(34.5")	H-2338mm(92.06")
	DLO:	W-641mm(25.25")	H-1607mm(63.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 3635 x 2426 (143 x 95)-SHD Design Pressure: 1915 Pa (40 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf)

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-210-3973-02

June 30, 2036

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com