

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012057.02-R3
DATE: 07/31/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1
REVISION DATE: 01/29/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "Norwood 3070" Aluminum Sliding Glass/Pocket Door Configuration: OXX Glazing: Insulating Glass (Tempered or Heat Strengthened or Annealed) Frame: W-3658mm(144") H-3658mm(144") DLO: W-1105mm(43.5") H-3442mm(135.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG55 3658 x 3658 (144 x 144)-SD Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 395 Pa(8.25 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01991010/W-1689
Expiration Date: **February 28, 2031**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023