NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012057.03-R3**
DATE:	**07/31/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Fleetwood**
CODE:	**1855-1**
REVISION DATE:	**01/29/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors **1 Fleetwood Way** **Corona, CA 92879**	**Series "Norwood 3070"** **Aluminum Sliding Glass/Pocket Door** Configuration: XXX Glazing: Insulating Glass (Tempered or Heat Strengthened or Annealed) Frame: W-3658mm(144") H-3658mm(144") DLO: W-1105mm(43.5") H-3442mm(135.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **CSA A440S1-09**	**Class LC-PG55 3658 x 3658 (144 x 144)-SD** **Design Pressure: 2633 Pa (55 psf)** **Negative Design Pressure: 2873 Pa (60 psf)** **Water Penetration Resistance Test Pressure: 395 Pa(8.25 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01991010/W-1689
Expiration Date: **February 28, 2031**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com