

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012081-R3  
DATE: 08/18/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wojan  
CODE: 2087-1  
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wojan Window &amp; Door Corporation</b> <b>217 Stover Road</b> <b>Charlevoix, MI 49720</b>	<b>Series "1550"</b> <b>Aluminum Double Hung Window</b>  Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-2311mm(91") Sash: W-1346mm(53") H-1143mm(45") DLO: W-1273mm(50.13") H-1057mm(41.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>H-C50 1422 x 2311 (56 x 91)</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa(7.52 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: D7205.02-501-44  
Expiration Date: April 30, 2026

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shelby", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)