

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012082-R4  
DATE: 08/18/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wojan  
CODE: 2087-1  
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wojan Window &amp; Door Corporation</b> <b>217 Stover Road</b> <b>Charlevoix, MI 49720</b>	<b>Series "2140"</b> <b>Aluminum Sliding Glass Door</b>  Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2213mm(87.13") H-2108mm(83") Panel: W-1105mm(43.5") H-2032mm(80") DLO: W-991mm(39") H-1918mm(75.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG40 2213 x 2108 (87 x 83)-SD</b> <b>Design Pressure: 1920 Pa (40 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 290 Pa(6.06 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: D5613.01-109-44  
Expiration Date: **March 31, 2026**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)