

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012115.01-R3
DATE: 09/05/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "4500" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1524mm(60") H-2515mm(99") DLO: W-1410mm(55.5") H-2400mm(94.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG100 1524 x 2515 (60 x 99)-FW Design Pressure: ±4800 Pa (100 psf) Canadian Air Infiltration/Exfiltration Level: Fixed Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C1065.01-602-44
Expiration Date: May 31, 2026

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com