NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012119.19-R4**
DATE:	**09/08/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Wincore**
CODE:	**1640-1**
REVISION DATE:	**06/15/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC **250 Staunton Turnpike** **Parkersburg, VA 26104**	**Series "5400/5400S"** **Vinyl Single Hung Window** Configuration: O/X Glazing: Insulated Glass (Annealed) Frame: W-1219mm(48.00") H-1016mm(40.00") DLO: W-1104mm(43.50") H-426mm(16.80")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class LC-PG45 1219 x 1016(48 x 40)-H** **Design Pressure: 2164 Pa (45 psf)** **Negative Design Pressure: 2633 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 359 Pa (7.50 psf)**

Product Tested By: Testing Evaluation Laboratory
Report No: TEL 02801062/TEL 02801063/W-1716/W-1920
Expiration Date: **July 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com