

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012145-R4
DATE: 09/21/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Wojan
CODE: 2087-1
REVISION DATE: 02/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wojan Window & Door Corporation 217 Stover Road Charlevoix, MI 49720	Series "4600" Aluminum Out-Swing Awning Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-914mm(36") Vent: W-1470mm(57.88") H-860mm(33.88") DLO: W-1346mm(53") H-737mm(29")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG40 1524 x 914 (60 x 36)-AP Design Pressure: ±1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing, Inc.
Report No: B9309.02-602-44
Expiration Date: **June 30, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC 03/30/2023