

# NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI012150-R6  
DATE: 09/29/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Wojan  
CODE: 2087-1  
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wojan Window &amp; Door Corporation</b> <b>217 Stover Road</b> <b>Charlevoix, MI 49720</b>	<b>Series "M85"</b> <b>Aluminum Horizontal Sliding Window</b>  Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1803mm(71") H-1524mm(60") Sash: W-908mm(35.75") H-1473mm(58") DLO: W-813mm(32") H-1391mm(54.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG25 1803 x 1524 (71 x 60)-HS</b> <b>HS-LC25 1803 x 1524 (71 x 60)</b> <b>Design Pressure: 1200 Pa (25 psf)</b> <b>Negative Design Pressure: 1200 Pa (25 psf)</b> <b>Water Penetration Resistance Test Pressure: 180 Pa(3.76 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: A6308.02-602-44  
Expiration Date: September 30, 2026

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC 03/30/2023