NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012507-R4**
DATE:	**02/04/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**09/03/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "Pro 700"** **Vinyl Awning Combination Window** Configuration: O/X/O Glazing: Insulating Glass (Annealed) Frame: W-1205mm(47.44") H-2273mm(89.50") DLO: W-1092mm(43") H-720mm(28.32")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **CSA A440-S1-09**	**Class LC-PG35 1205 x 2273 (48 x 90)-AP** **Design Pressure: ±1680 Pa (35 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Architectural Testing Incorporated
Report No: E2696.01-901-44/NCTL-310-2423 (Gateway)/W-1724/W-2034
Expiration Date: **November 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com