

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012751-R5  
**DATE:** 07/26/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Reeb  
**CODE:** 850-1  
**REVISION DATE:** 04/08/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Reeb Millwork Corporation</b> <b>7475 Henry Clay Boulevard</b> <b>Liverpool, NY 13088</b>	<b>Steel Opaque In-Swing</b> <b>Side-Hinged Door w/Sidelites</b>  Glazing: Insulating Glass (Tempered)  Frame: W-1718mm(67.63") H-2084mm(82.03") Panel: W-914mm(36") H-2013mm(79.25") Sidelite: W-354mm(13.94") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b> (applicable sub-sections)	<b>Manufactured Housing:</b> <b>Wind Zone III</b> <b>Design Wind Pressure Rating</b> <b>+58/-58 psf</b>

Product Tested By: Architectural Testing, Inc.  
Report No: A4929.01-501-47/W-1737/W-2157  
Expiration Date: **July 31, 2026**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)