NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI012879.01-R2

DATE: 10/01/2015

CERTIFICATION PROGRAM: Structural

COMPANY: YKK

CODE: 1772-1

REVISION DATE: 06/20/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc.	Series "YES SSG TUH" Aluminum
270 Riverside Pkwy, Suite 100	Project-Out Awning Window
Austell, GA 30168	w/2 Point Cam Lock &
	4-Bar Hinge or 5-Bar Hinge
	Configuration: X Glazing: IG-1/4" Heat Strengthened Glass/Laminate- 5/32" Heat Strengthened Glass/0.090" DuPont PVB Interlayer/5/32" Heat Strengthened Glass
	Frame: W-1524mm(60") H-914mm(36")
	Vent: W-1511mm(59.5") H-902mm(35.5")
	DLO: W-1429mm(56.25") H-819mm(32.25")
SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-05 TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated

Report No: D5961.09-550-18/D5961.10-550-18/D5961.01-550-18/D5961.05-550-

18/D5961.06-550-18/D5961.08-550-18

Expiration Date: April 30, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com