

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012879.04-R2  
**DATE:** 01/23/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** YKK  
**CODE:** 1772-1  
**REVISION DATE:** 06/20/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>YKK AP America, Inc.</b> <b>270 Riverside Pkwy, Suite 100</b> <b>Austell, GA 30168</b>	<b>Series "YES SSG TUH"</b> <b>Aluminum Project-Out Awning Window</b> <b>w/4-Point Multi-Lock</b>  Configuration: X/X/X Glazing: 1/4" Tempered Glass/Laminate-5/32" Heat Strengthened Glass/0.060" DuPont PVB Interlayer/5/32 Heat" Strengthened Glass  Frame: W-1657mm(65.25") H-3032mm(119.38") Vent: W-1511mm(59.5") H-902mm(35.5") DLO: W-1429mm(56.25") H-819mm(32.25")
SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/E1996-05</b> <b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3830 Pa (80 psf)</b> <b>Wind Zone 4 - Missile Level A</b> <b>Small Missile Impact Rated</b>

Product Tested By: Architectural Testing Incorporated  
Report No: D5961.02-550-18/D5961.01-550-18/D5961.05-550-18/D5961.06-550-18/D5961.08-550-18  
Expiration Date: April 30, 2026

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)