NOTICE OF PRODUCT CERTIFICATION



This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESCRIPTION			
YKK AP America, Inc.		Series "YES SSG TUH"			
270 Riverside Pkwy, Suite 100		Aluminum Out-Swing Casement Window			
Austell, GA 30168		w/4-Point Multi-Lock			
		Configuration: X Glazing: IG-1/4" Heat Strengthened Glass/Laminate- 5/32" Heat Strengthened Glass/0.090" DuPont PVB Interlayer/5/32" Heat Strengthened Glass			
		Frame:	W-914mm(36")	H-1524mm(60")	
		Vent:	W-902mm(35.5")	H-1511mm(59.5")	
		DLO:	W-819mm(32.25")	H-1429mm(56.25")	
SPECIFICATION		PRODUCT RATING			
ASTM E1886-05/E1996-05 TAS 201/202/203-94		Design Pressure: ±3830 Pa (80 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated			
Product Tested By: Report No: Expiration Date:	Architectural Testing Inco D5961.03-550-18/D5961. May 31, 2026	-			
Administrator's Sign	ature:	n.			

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com