

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI012889.02-R2</u>
DATE:	<u>01/23/2018</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>YKK</u>
CODE:	<u>1772-1</u>
REVISION DATE:	<u>06/20/2022</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>YKK AP America, Inc.</p> <p>270 Riverside Pkwy, Suite 100</p> <p>Austell, GA 30168</p>	<p style="text-align: center;">Series "YES SSG TUH"</p> <p style="text-align: center;">Aluminum Out-Swing Casement Window</p> <p style="text-align: center;">w/4-Point Multi-Lock</p> <p style="text-align: center;">Configuration: X/X/X</p> <p style="text-align: center;">Glazing: IG-1/4" Tempered Glass/Laminate-5/32" Heat Strengthened Glass/0.060" DuPont PVB Interlayer/5/32 Heat" Strengthened Glass</p> <p>Frame: W-3076mm(121.13") H-1685mm(66.38")</p> <p>Vent: W-902mm(35.5") H-1511mm(59.5")</p> <p>DLO: W-819mm(32.25") H-1429mm(56.25")</p>
SPECIFICATION	PRODUCT RATING
<p>ASTM E1886-05/E1996-05</p> <p>TAS 201/202/203-94</p>	<p>Design Pressure: ±3830 Pa (80 psf)</p> <p>Wind Zone 4 - Missile Level A</p> <p>Small Missile Impact Rated</p>

Product Tested By: Architectural Testing Incorporated
 Report No: D5961.07-550-18/D5961.03-550-18
 Expiration Date: May 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com