

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012920-R2
DATE: 10/28/2015
CERTIFICATION PROGRAM: Structural
COMPANY: LAS Enterprises
CODE: 1124-1
REVISION DATE: 01/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
LAS Enterprises 2413 L & A Road Metairie, LA 70001	Series "Weathergard II" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Heat Strengthened) Frame: W-2000mm(79") H-2000mm(79") DLO: W-1830mm(72") H-1670mm(65.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG85 2000 x 2000 (79 x 79)-FW FW-HC85 2000 x 2000 (79 x 79) Design Pressure: 4080 Pa (85 psf) Negative Design Pressure: 4080 Pa (85 psf) Water Penetration Resistance Test Pressure: 720 Pa (15 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Air-Ins, Inc.
Report No: AI-02980-A1/W-1922
Expiration Date: December 31, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com