

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012922-R3  
DATE: 10/28/2015  
CERTIFICATION PROGRAM: Structural  
COMPANY: LAS Enterprises  
CODE: 1124-1  
REVISION DATE: 01/25/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>LAS Enterprises</b> <b>2413 L &amp; A Road</b> <b>Metairie, LA 70001</b>	<b>Series "Weathergard II"</b> <b>Vinyl Double Hung Window</b>  Configuration: X/X Glazing: Insulating Glass (Annealed)  Frame: W-1000mm(39.37") H-1600mm(63") Sash: W-927mm(36.49") H-772mm(30.39")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG70 1000 x 1600 (39 x 63)-H</b> <b>Design Pressure: 3360 Pa (70 psf)</b> <b>Negative Design Pressure: 3360 Pa (70 psf)</b> Water Penetration Resistance Test Pressure: 730 Pa (15.0 psf) Canadian Air Infiltration/Exfiltration Level = A3

Product Tested By: Air-Ins, Inc.  
Report No: AI-03661-G1  
Expiration Date: **December 31, 2024**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)