NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012930.03-R4**
DATE:	**11/15/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**03/27/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "ComfortSmart 3 Lite Slider"** **Vinyl Horizontal Sliding Window** Configuration: XXX Glazing: Insulating Glass (Annealed) Frame: W-2757mm(108.56") H-1589mm(62.56") Panel: W-911mm(35.88") H-1486mm(58.5") DLO: W-829mm(32.63") H-1403mm(55.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05** **CSA A440S1-09**	**Class R-PG20 2757 x 1589 (109 x 63)-HS** **HS-R20 2757 x 1589 (109 x 63)** **Design Pressure: 960 Pa (20 psf)** **Negative Design Pressure: 960 Pa (20 psf)** **Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-18424-1/W-1874/W-1986
Expiration Date: **December 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com