

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012930.08-R2  
**DATE:** 06/22/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Great Lakes  
**CODE:** 1411-1  
**REVISION DATE:** 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Great Lakes Window</b> <b>30499 Tracy Road</b> <b>Walbridge, OH 43465</b>	<b>Series "ComfortSmart"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm(44") Panel: W-765mm(30.13") H-1013mm(39.87") DLO: W-686mm(27") H-932mm(36.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>CSA A440S1-09</b>	<b>Class R-PG50 1600 x 1118 (63 x 44)-HS</b> <b>HS-R50 1600 x 1118 (63 x 44)</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 3120 Pa (65 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-19162-1/NCTL-110-18421-1/W-2071  
Expiration Date: **January 31, 2028**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)