

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012949.05-R4  
DATE: 01/05/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Atrium  
CODE: 1373-1  
REVISION DATE: 11/02/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Atrium Companies, Inc.</b> <b>9001 Ambassador Row</b> <b>Dallas, TX 75247</b>	<b>Series "8900/90/8000/1800/3900"</b> <b>Twin Vinyl Double Hung Window</b> <b>w/Transom &amp; Finless Installation</b>  Configuration: O/X/X/X/X Glazing: Insulating Glass (Annealed)  Frame: W-1829mm(72") H-2743mm(108")  Ind: W-908mm(35.75") H-1816mm(71.5") TR: W-1829mm(72") H-914mm(36")  DLO: W-1694mm(66.69") H-779mm(30.67")

SPECIFICATION	PRODUCT RATING
<b>AAMA 450-10</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Applied Rating: R40</b> <b>Mulled Fenestration Rating: R40</b> <b>Individual Product Rating:</b> <b>Class LC-PG60 914 x 1880* (36 x 74*)-H</b> <b>Class R-PG50 1829 x 914 (72 x 36)-FW</b>

Product Tested By: Architectural Testing, Inc.  
Report No: B8804.01-801-47/ B8805.01-801-47/B8802.01-801-47/W-1839/W-2009  
Expiration Date: **January 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122