

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012986-R4
DATE: 01/12/2016
CERTIFICATION PROGRAM: Struct/Impact
COMPANY: Case Group
CODE: 1032-1
REVISION DATE: 05/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
The Case Group, LLC dba Case Window & Door 195 Cohoes Avenue Green Island, NY 12183	Impact Rated Glazed Inswing & Outswing Steel Door Configuration: X Glazing: IG-1/4" Tempered Glass/Laminate-1/4" Heat Strengthened Glass/0.090" SentryGlas SG5000 Interlayer/1/4" Heat Strengthened Glass Frame: W-1219mm(48") H-2918mm(114.88") Panel: W-1169mm(46") H-2848mm(112.5") DLO: W-999mm(39.38") H-2678mm(105.38")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00/E547-00 ASTM E1886-05/E1996-05/09	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 576 Pa(12 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4007-01
Expiration Date: **July 31, 2025**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com