

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012986.02-R4  
**DATE:** 01/12/2016  
**CERTIFICATION PROGRAM:** Struct/Impact  
**COMPANY:** Case Group  
**CODE:** 1032-1  
**REVISION DATE:** 05/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>The Case Group, LLC</b> <b>dba Case Window &amp; Door</b> <b>195 Cohoes Avenue</b> <b>Green Island, NY 12183</b>	<b>Impact Rated Glazed</b> <b>Inswing &amp; Outswing Steel Door</b>  Configuration: X Glazing: Monolithic-1/4" Heat Strengthened Glass/0.090" SentryGlas SG5000 Interlayer/1/4" Heat Strengthened Glass Frame: W-1219mm(48") H-2918mm(114.88") Panel: W-1169mm(46") H-2848mm(112.5") DLO: W-102mm(4") H-956mm(37.63")

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04/E330-02/E331-00/E547-00</b> <b>ASTM E1886-05/E1996-05/09</b>	<b>Design Pressure: +55/-55 psf</b> <b>Wind Zone 4-Missile Level D</b> Water Penetration Resistance Test Pressure: 480 Pa(10 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4007-01  
Expiration Date: **July 31, 2025**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)