

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012987-R4  
**DATE:** 01/12/2016  
**CERTIFICATION PROGRAM:** Struct/Impact  
**COMPANY:** Case Group  
**CODE:** 1032-1  
**REVISION DATE:** 05/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION  |
|--|--|
| <b>The Case Group, LLC</b><br><b>dba Case Window &amp; Door</b><br><b>195 Cohoes Avenue</b><br><b>Green Island, NY 12183</b> | <b>Impact Rated Steel Fixed Window</b><br><br>Configuration: O<br>Glazing: IG-1/4" Tempered Glass/Laminate-1/4" Heat Strengthened Glass/0.090" SentryGlas SG5000 Interlayer/1/4" Heat Strengthened Glass<br><br>Frame: W-3505mm(138") H-2134mm(84")<br>DLO: W-3405mm(134") H-2034mm(80") |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>ASTM E1886-05/E1996-05/09</b> | <b>Class CW-PG40 3505 x 2134 (138 x 84)-FW</b><br><b>Design Pressure: 1915 Pa (40 psf)</b><br><b>Positive Design Pressure: 2064 Pa (43 psf)</b><br><b>Negative Design Pressure: 2064 Pa (43 psf)</b><br><b>Wind Zone 4-Missile Level D</b><br><b>Water Penetration Resistance Test Pressure: 576 Pa(12 psf)</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4007-02  
Expiration Date: **July 31, 2025**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)