

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012987.01-R4
DATE: 01/20/2016
CERTIFICATION PROGRAM: Struct/Impact
COMPANY: Case Group
CODE: 1032-1
REVISION DATE: 05/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
The Case Group, LLC dba Case Window & Door 195 Cohoes Avenue Green Island, NY 12183	Impact Rated Steel Fixed Window Configuration: O Glazing: IG-1/4" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.060" SentryGlas SG5000 Interlayer/3/16" Heat Strengthened Glass Frame: W-891mm(35.06") H-3481mm(137.06") DLO: W-791mm(31.13") H-3381mm(133.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05/09	Class CW-PG55 891 x 3481 (35 x 137)-FW Design Pressure: ±2640 Pa (55 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 576 Pa(12 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4012-01A/NCTL-210-4007-02
Expiration Date: July 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com