

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012992-R3
DATE: 01/14/2016
CERTIFICATION PROGRAM: Struct/Impact
COMPANY: Case Group
CODE: 1032-1
REVISION DATE: 05/01/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| The Case Group, LLC dba Case Window & Door 195 Cohoes Avenue Green Island, NY 12183 | Series "Hurricane Structural" Impact Rated Steel Fixed Window Configuration: O Glazing: IG-1/4" Tempered Glass/Laminate-1/4" Heat Strengthened Glass/0.090" SentryGlas SG5000 Interlayer/1/4" Heat Strengthened Glass Frame: W-1233mm(48.56") H-3036mm(119.5") DLO: W-1158mm(45.56") H-2956mm(116.38") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05/09 | Class R-PG50 1233 x 3036 (49 x 120)-FW Design Pressure: 2400 Pa (50 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 720 Pa(15 psf) |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4007-03
Expiration Date: **July 31, 2025**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com