

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013023-R3
DATE: 02/23/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247 | Series "705/755" Vinyl Awning Window w/Fin Installation Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-914mm(36") Vent: W-1275mm(50.19") H-876mm(34.5") DLO: W-1162mm(45.75") H-756mm(29.75") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class LC-PG35 1321 x 914 (52 x 36)-AP Design Pressure: ±1676 Pa (35 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) |

Product Tested By: Architectural Testing, Inc.
Report No: E1448.01-801-47/W-2009
Expiration Date: **October 31, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com