

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013023.03-R3  
**DATE:** 02/23/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Atrium  
**CODE:** 1373-1  
**REVISION DATE:** 03/06/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Atrium Companies, Inc.</b> <b>9001 Ambassador Row</b> <b>Dallas, TX 75247</b>	<b>Series "705/755"</b> <b>Vinyl Awning Window</b> <b>w/Finless Installation</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48")      H-914mm(36") Vent: W-1172mm(46.19")      H-865mm(34.09") DLO: W-1060mm(41.75")      H-756mm(29.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG35 1219 x 914 (48 x 36)-AP</b> <b>Design Pressure: ±1676 Pa (35 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.  
Report No: E1448.01-801-47/W-2009  
Expiration Date: **October 31, 2027**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)