

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013027.01-R3
DATE: 02/25/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247 | Series "700/750" Vinyl Casement Window w/Finless Installation Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") Vent: W-875mm(34.44") H-1781mm(70.13") DLO: W-762mm(30") H-1670mm(65.75") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class LC-PG50 1829 x 1829 (72 x 72)-C Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) |

Product Tested By: Architectural Testing, Inc.
Report No: E1444.01-801-47/E1438.01-801-47 (Gateway)/W-1996
Expiration Date: **November 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com