

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013028-R3
DATE: 02/25/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Atrium
CODE: 1373-1
REVISION DATE: 07/26/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Atrium Companies, Inc. 9001 Ambassador Row Dallas, TX 75247	Series "700/750" Vinyl Casement Window w/Fin Installation Configuration: XOOX Glazing: Insulating Glass (Annealed) Frame: W-3048mm(120") H-1829mm(72") Vent: W-729mm(28.69") H-1791mm(70.5") DLO: W-622mm(24.5") H-1670mm(65.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG35 3048 x 1829 (120 x 72)-C Design Pressure: ±1675 Pa (35 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: E1439.01-801-47/E1438.01-801-47 & E1449.01-801-47/W-1996
Expiration Date: **November 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com