

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013098-R2  
**DATE:** 03/31/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Cantera  
**CODE:** 549-1  
**REVISION DATE:** 01/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Cantera Doors</b> <b>427 Ranch Road 620 S. Suite C</b> <b>Lakeway, TX 78734</b>	<b>Steel Out-Swing Side-Hinged</b> <b>Double Door Assembly</b> <b>w/Arch Transom &amp; Surface Bolts</b>  Configuration: O/OX Glazing: Monolithic-3/16" Annealed Glass/0.090" Kuraray SG PVB Interlayer/3/16" Annealed Glass  Frame: W-1905mm(75") H-4001mm(157.5")  Panel: W-927mm(36.5") H-3034mm(119.43")  DLO: W-572mm(22.5") H-2705mm(106.5") Transom DLO: W-1784mm(70.25") H-832mm(32.75")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +45/-70 psf</b> <b>Positive Structural Design Pressure: +70 psf</b> <b>Negative Structural Design Pressure: -70 psf</b> <b>Water Penetration Resistance Test Pressure: 6.75 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: Certified Testing Laboratories, Inc.  
Report No: CTLA 1762W-4  
Expiration Date: March 31, 2034

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway  
Hayes, VA 23072**

**Tel: (804) 684-5124**

**Email: [nami@namiinc.com](mailto:nami@namiinc.com)**

NOPC-03/30/2023