

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013137-R4  
**DATE:** 04/15/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** BlueLinx  
**CODE:** 1366-1  
**REVISION DATE:** 07/27/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>BlueLinx Company</b> <b>225 Collins Road</b> <b>Elkhart, IN 46516</b>	<b>“Gladiator/Finishield”</b> <b>25 Gauge Thin Stile &amp; Rail</b> <b>Outswing Opaque Steel Door</b> Configuration: X  Frame: W-952mm(37.48") H-2050mm(80.71") Panel: W-908mm(35.79") H-2012mm(79.21")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95/02/12</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b> (applicable sections)	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b> <b>Design Wind Pressure Rating:</b> <b>+58/-58 psf</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2014-023  
Expiration Date: January 31, 2026

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)